SRI BAALAMURUGAN BOREWELLS

4, gangamma Compound, Opp. Canara Bank Bus Stop, Bellary Main Road, Helbal Bangalore - 24
Mob : 9845020536, 9901920004

WORK REPORT

No.

Date :

Babanagara 3rd cross

S.No.	Particulars	Rft :	Water Yield	Remarks
1.	Size of The Borewell	165 mm		
2.	Total Deapth of The Borewell	980'		
3.	MS Casing Erected	173'		
4.	1st Water Source at the Deapth	291'		
5.	2nd Water Source at the Deapth	516'		
6.	3rd Water Source at the Deapth	725'		
7.	4th Water Source at the Deapth	916'		
8.	If any Silt, Boulders at the Deapth	—		
9.	Nature of Water	Sweet water		
10.	Moter Pump to be Used	15 X 8 25 Stage		
11.	Any other Remarks	—		
12.	Total Yield of the Borewell	2'-6"		

Thanking You

Yours faithfully
For Sri Baalamurugan Borewells

OUND WATER SURVEY REPORT

OPEN WELL/ BOREWELL
DATA OF SURVEY

a) Name of the Party : AEE, Byatarayana pura - Sub Division

b) Location of the Site : BBMP Ward No-5

c) Area of the land : BBABA Nagara 3rd Cross.

INVESTIGATION REPORT

1) GEOLOGY OF THE AREA :

2) Recommended Site for drilling :

3) Total depth to be drilled : 800' to 900'

4) Approx. casing pipe required : 80' to 150'

5) No. of water bearing Zones : — 1 —

6) No. of favourable spots marked : — 1 —

7) Qty. of water expected : 1½" to 2"0

8) Method of survey carried out : GEO

9) Remarks :

P.T.O. : Terms & Conditions

HYDROGEOLOGIST
(M.G. RAJASHEKHAR, M.Sc., DEG., F.G.S.)

BOREWELL SITE PLAN



ward no - 65

BABA Nagar
5th cross

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ. ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

Assistant Executive Engineer
Byatarayanapura Sub Division
B.B.M.P Bangalore

N.No. 5 ಬಾ.ಬಾ ನಗರ 5th ಕ್ರಾಸ್ ಜಿಗಣಿ ಬಳಿ

AE-Dy

Assistant Executive Engineer
Jyatarayanapura Sub Division
B.B.M.P. Bangalore